



# POOL INSPECTION RECORD

POST THIS CARD INSIDE THE ELECTRIC PANEL  
**WORK MAY NOT BE COVERED BEFORE INSPECTION**  
TO REQUEST AN INSPECTION CALL 480-312-5796

[http://eservices.scottsdaleaz.gov/permits/permitkeycode\\_lookup.asp](http://eservices.scottsdaleaz.gov/permits/permitkeycode_lookup.asp)

**Sample Only**  
not for use

ADDRESS: \_\_\_\_\_

PERMIT: \_\_\_\_\_

INSP TYPE	DESCRIPTION	COMMENTS	DATE	INSPECTOR
--------------	-------------	----------	------	-----------

## BEFORE STARTING ANY CONSTRUCTION - REQUEST 042

042	PRE-SITE INSPECTION	SEE THE NOTE & INSTRUCTIONS BELOW		
001	POOL ROUGH (PRE-GUNITE)	INSPECTED B-4 PLACING GUNITE		
010	UNDERGROUND ELECTRIC	INSPECTED B-4 PLACING GUNITE		

## BEFORE REQUESTING POOL FINAL 002 - REQUEST 031

031	ON-SITE FINAL (PRE-PLASTER)	SEE THE NOTE & INSTRUCTIONS BELOW		
002	POOL FINAL (PRE-PLASTER)	INSPECTED B-4 PLASTERING, AFTER 031		

## NATURAL GAS, LP GAS & MECHANICAL REQUIRE SEPARATE PERMITS

021	NATURAL GAS LINE	SEE INSTRUCTIONS BELOW		
022	PROPANE (LP) GAS	SEE INSTRUCTIONS BELOW		
028	FINAL MECHANICAL (HEATER)	SEE INSTRUCTIONS BELOW		

**\*Deposits & After Hour Fee's can be paid at Inspection Services, 9191 E. San Salvador, City Corp Yard - 2nd Floor**

PERMITTEE MUST CALL FOR ONE OR MORE OF THE FOLLOWING INSPECTIONS WHEN WORK IS READY FOR INSPECTION. A COPY OF THE CITY APPROVED BUILDING PLAN, SITE PLAN, & THIS INSPECTION CARD MUST BE ON THE JOBSITE FOR EVERY REQUESTED INSPECTION.

**NOTE**

**THE 042 AND 031 INSPECTIONS ON POOLS ARE ONLY REQUIRED WHEN THE POOL IS PERMITTED AND BUILT AFTER THE HOUSE HAS BEEN COMPLETED. POOLS CONSTRUCTED WITH THE HOUSE WILL RECEIVE THE 042 AND 031 WHEN THESE INSPECTIONS ARE PERFORMED ON THE HOUSE.**

**042 PRE-SITE** – Required prior to beginning any site grading, excavation or construction. Check city sidewalks, property access, native plants and existing site drainage.

**001 POOL ROUGH (PRE-GUNITE)** - Check setback of the pool per city approved site plan. Check placement of steel per city approved plans and details.

**010 ELECTRIC UNDERGROUND** - Check underground electric for depth, size and type. Check circuit conductors. Check grounding and bonding of any metal within 5 feet of waters edge. Check to see that all glass within 5 feet of waters edge is safety glass.

**031 FINAL ON-SITE** – Required prior to requesting the pool final. Check city sidewalks for damage during pool construction. Check native plants and proper site drainage.

**002 POOL FINAL (PRE-PLASTER)** - Check all fencing and gates. Check barrier between house and pool for proper alarms, doors, etc. Check final electric connection at pool equipment and electric panel. Check vacuum breaker. Check material clean-up. (See Inspection 028)

**021 NATURAL GAS LINE** - Check piping for size & type. Pressure test required at final inspection.

**022 PROPANE (LP) GAS LINE** - Check piping for size & type. Pressure test required at final inspection. Call Rural Metro for additional LP requirements.

**028 FINAL MECHANICAL** - Check pool heater location & venting to assure compliance with mechanical code and city approved plans.

THE ISSUANCE OF THIS PERMIT DOES NOT IMPLY, THAT IF THE INSPECTOR FINDS THE TECHNICAL CONSTRUCTION INFORMATION CONTAINED WITHIN THE PLANS AND SPECIFICATIONS DOES NOT MEET THE MINIMUM REQUIREMENTS OF THE CITY CODES AND AMENDING ORDINANCES, THE INSPECTION WILL AUTOMATICALLY BE APPROVED. ALL WORK MUST MEET MINIMUM REQUIREMENTS FOR CONSTRUCTION, AS OUTLINED IN THE CITY CODES AND AMENDING ORDINANCES. IT IS AGREED THAT THIS WORK WILL BE DONE IN CONFORMITY WITH THE LAWS OF THE CITY OF SCOTTSDALE, MARICOPA COUNTY AND THE